CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/PRN/W No.16/2019-20

20.02.2020

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Executive Engineer,** Project Division RR Nagar Zone, BBMP, Bangalore.

Contractor : **Sri. Purushotham Raju N (Nadimpalli Purushotham Raju),** Contractor, Bangalore

Name of the work : Construction of MPED Building (Govt School) At Jalahalli Village in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete (Ground Floor-Beam)

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{25}

Compressive Strength as on : 7th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.02.2020	20.02.2020	8.295	395.6	17.58
2	13.02.2020	20.02.2020	8.225	374.5	16.64
3	13.02.2020	20.02.2020	8.265	382.6	17.00

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Assistant Executive Engineer
R.R. Nagar Project Sub-Division-01
Bruhat Bengaluru Mahanagara Palike

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/PRN/W No.16/2019-20

12.03.2020

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Executive Engineer,** Project Division RR Nagar Zone, BBMP, Bangalore.

Contractor : **Sri. Purushotham Raju N (Nadimpalli Purushotham Raju),** Contractor, Bangalore

Name of the work : Construction of MPED Building (Govt School) At Jalahalli Village in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete (Ground Floor-Beam)

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{25}

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	13.02.2020	12.03.2020	8.336	622.5	27.67
2	13.02.2020	12.03.2020	8.352	605.2	26.90
3	13.02.2020	12.03.2020	8.314	615.6	27.36

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Assistant Executive Engineer
R.R. Nagar Project Sub-Division-01
Bruhat Bengaluru Mahanagara Palike

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner

CIVIL QUALITY CONSULTANTS & ENGINEERS

(Buildings Geo-Tech & Highway Materials Testing Laboratory)
An ISO 9001: 2015 Certified Company
NABL Accredited As Per ISO/IEC : 17025:2005 Laboratory

JAS-ANZ
ISO 9001:2000 CERTIFIED

Job No.: CQCE/BBMP/PRN/W No.16/2019-20

14.03.2020

TEST REPORT ON COMPRESSIVE STRENGTH OF CONCRETE CUBES

Client : **Executive Engineer,** Project Division RR Nagar Zone, BBMP, Bangalore.

Contractor : **Sri. Purushotham Raju N (Nadimpalli Purushotham Raju),** Contractor, Bangalore

Name of the work : Construction of MPED Building (Govt School) At Jalahalli Village in Ward No.16, BBMP, Bangalore.

Sample ID : Cement Concrete (Ground Floor- Slab)

Size of cubes : 150mmx150mmx150mm

Cross Sectional Area : 22500 mm^2

Technical Reference : IS: 516-1959 (Reaffirmed 2008)

Grade of Concrete : M_{25}

Compressive Strength as on : 28th day

Sl.No.	Date of casting	Date of testing	Weight of cube (Kg)	Failure load (KN)	Compressive strength (N/mm^2)
1	15.02.2020	14.03.2020	8.395	622.5	27.67
2	15.02.2020	14.03.2020	8.352	631.2	28.05
3	15.02.2020	14.03.2020	8.347	615.8	27.37

Note:

1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
3. Any Query regarding the report must be reported within 30 days from the date of testing.

Assistant Executive Engineer
R.R. Nagar Project Sub-Division-01
Bruhat Bengaluru Mahanagara Palike

For CIVIL QUALITY CONSULTANTS & ENGINEERS

Authorised Signatory

Office & Laboratory : # 133, Bhuvaneshwarinagar, Dodda Basti Main Road, Bangalore - 560 056.
e-mail: civilqualityconsultants@gmail.com Ph: 080-23240644 / Mob: 8553518550

Scanned with CamScanner